

SECTION 58

PRESERVATIVE TREATMENT OF LUMBER, TIMBER AND PILING

(Shall Apply Without Modification)

SECTION 59

PAINTING

(Shall Apply Without Modification)

SECTION 60

(Blank)

SECTION 61

CULVERT AND DRAINAGE PIPE JOINTS

(Shall Apply Without Modification)

SECTION 62

ALTERNATIVE CULVERTS

(Shall Apply Without Modification)

SECTION 63

CAST-IN-PLACE CONCRETE PIPE

(Shall Apply Without Modification)

SECTION 64

PLASTIC PIPE

(Shall Apply Without Modification)

SECTION 65

REINFORCED CONCRETE PIPE

65-1.02A(1) Circular Reinforced Concrete Pipe (Designated or Selected by Class)

Concrete pipe shall meet the minimum strength requirements of Class III pipe in accordance with the requirements of AASHTO Designation M170, unless a stronger class of pipe is shown on the plans. Non-reinforced precast concrete pipe shall not be used in the public right-of-way.

SECTION 66

CORRUGATED METAL PIPE
(Shall Apply Without Modification)

SECTION 67

STRUCTURAL METAL PLATE PIPE
(Shall Apply Without Modification)

SECTION 68

SUBSURFACE DRAINS
(Shall Apply Without Modification)

SECTION 69

OVERSIDE DRAINS
(Shall Apply Without Modification)

SECTION 70

MISCELLANEOUS FACILITIES
(Shall Apply Without Modification)

SECTION 71

(Blank)

SECTION 72

SLOPE PROTECTION
(Shall Apply Without Modification)

SECTION 73

CONCRETE CURBS AND SIDEWALKS
(Shall Apply Without Modification)

73-1.05 Curb Construction

Weakened plane joints shall conform to City Standard Plans. Premolded expansion joint fillers are not allowed.

73-1.05B Extruded or Slip-Formed Curb Construction

Weakened plane joints shall conform to City Standard Plans. Premolded expansion joint fillers are not allowed.

73-1.06 Sidewalk, Gutter Depression, Island Paving, Curb Ramp (Wheelchair Ramp) and Driveway Construction

Weakened plane joints shall conform to City Standard Plans. Premolded expansion joint fillers are not allowed.

SECTION 74

PUMPING PLANT EQUIPMENT
(Shall Apply Without Modification)

SECTION 75

MISCELLANEOUS METAL
(Shall Apply Without Modification)

75-1.02 Miscellaneous Iron and Steel

Drainage inlet frames and grates shall be galvanized in accordance with the provisions of Section 75-1.05, "Galvanizing".

SECTIONS 76 through 79
(Blank)

SECTION 80

FENCES
(Shall Apply Without Modification)