

SECTION 24

LIME TREATMENT (Shall Apply Without Modification)

SECTION 25

AGGREGATE SUBBASES

25-1.02a Aggregate Subbases

Aggregate subbase shall conform to the grading and quality requirements shown in the Table for Class 2 Aggregate Subbase.

25-1.05 Compacting

The surface of the aggregate subbase shall not be higher than the grades established by the Engineer or shown on the plans. Low areas shall be filled with aggregate base during the spreading operation for aggregate base.

SECTION 26

AGGREGATE BASES

26-1.02B Class 2 Aggregate Base

Aggregate base shall conform to the grading and quality requirements shown in the Table for Class 2, 3/4 " maximum aggregate base.

26-1.04 Spreading

The aggregate base under the gutter shall be spread and compacted at the same time as the roadway aggregate base.

26-1.05 Compacting

The surface of the aggregate base shall not be higher than the grades established by the Engineer or shown on the plans. Low areas shall be filled with asphalt concrete during the spreading operation for the base course of asphalt concrete.

The work specified in this Section includes furnishing, spreading and compacting mineral aggregate on the subgrade in accordance with these Specifications.

SECTION 27

CEMENT TREATED BASES
(Shall Apply Without Modification)

SECTION 28

LEAN CONCRETE BASE
(Shall Apply Without Modification)

SECTION 29

TREATED PERMEABLE BASES
(Shall Apply Without Modification)

SECTION 30 through 36
(Blank)

SECTION 37

BITUMINOUS SEALS
(Shall Apply Without Modification)

SECTION 38
(Blank)

SECTION 39

ASPHALT CONCRETE

39-2.02 Aggregate

The aggregate for the surface course shall conform to the grading and quality requirements of ½" maximum, medium grading, Type B asphalt concrete.

The aggregate for the base course shall conform to the grading and quality requirements of ¾" maximum, medium grading, Type B asphalt concrete.

39-4.02 Prime Coat and Paint Binder

Prime coats will not be required.